

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

September 12, 2011

ZEROPOINT MFG. CO., INC. JON S. JANKOWSKI 600 E KEEFE AVE MILWAUKEE WI 53212

Re: Description: WATER TREATMENT DEVICE - POE SOFTENER

Manufacturer: ZEROPOINT MFG. CO., INC.

Product Name: FILTERITE SERIES

Model Number(s): ZM25124, ZM25132, ZM25140, ZM25150, ZM25160, ZM25124M, ZM25132M,

ZM25140, ZM25150M AND ZM25160M

Product File No: 20110245

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2016.

This approval supersedes the approval issued on August 1st, 2006 under product file number 20050293.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- > These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 11024501.DOC

Zeropoint Manufacturing Company Inc.

September 12th, 2011

Page 2 of 2

Product File No.: 20110245

WATER SOFTENING CAPABILITIES PRODUCT FILE NUMBER 20110245 TABLE 1 OF 1

Model Numbers		Capacity*						Flow Rate vs.
Filterite Series		Rating 1		Rating 2		Rating 3		Pressure Loss
Metered	Time Clock	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
ZM5624M	ZM5624	13,000	4.1	18,300	6.8	25,700	11.3	8.4 @ 9.7
ZM5632M	ZM5632	17,300	5.5	24,500	9.1	33,400	15.0	10 @ 10.7
ZM5640M	ZM5640	19,000	6.0	26,900	10.0	36,700	16.5	10 @ 11.3
ZM5650M	ZM5650	25,900	8.2	36,700	13.6	50,000	22.5	9.7 @ 10.3
ZM5660M	ZM5660	34,500	10.9	48,900	18.2	66,700	30.0	12 @ 11.6

^{*} The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with WQA Standard S-100-85.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Safety and Professional Services
(608) 267-1401 **Phone**(608) 267-9566 **Fax**glen.schlueter@wi.gov **Email**8:00AM – 4:30PM CDT **Work Hours**

GWS:gws